



CERTIFICATE OF ANALYSIS

Customer : Strategic Environmental
25 Butternut Lane
Bayville, NJ 08721

Project ID : Deal BOE, 201 Rosed Ave.
PAS Project ID : P20-05763

Matrix : Drinking Water
Report Date : 8/6/2020

PAS Sample ID	Client ID	Analysis	Results	Units	DF	PQL	MDL	MCL	Method	Date Sampled	Date Analyzed
P20-05763-01	DS #1 N/E Hall	Lead	1.96 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 07:51	8/3/20 19:52
P20-05763-02	DS #2 Locker Room	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 07:53	8/3/20 19:57
P20-05763-03	DS #3 Room 15	Lead	10.9	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 07:55	8/3/20 20:01
P20-05763-04	DS #5 Principal Office	Lead	4.70	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 07:56	8/3/20 20:05
P20-05763-05	DS #6 Teacher Break Room	Lead	1.71 J	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 07:58	8/3/20 20:09
P20-05763-06	DS #11 Boiler Room	Lead	7.45	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 08:00	8/3/20 20:33
P20-05763-07	DS #12 Kitchen Hall	Lead	ND	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 08:02	8/3/20 20:37
P20-05763-08	DS #13 Kitchen Sink	Lead	2.21	ug/L	1	2.00	0.900	15.0 *	SM 3113 B	7/30/20 08:09	8/3/20 21:41

Except for the parameters tested, PAS makes no representation as to the fitness or quality of the water sample taken.

PQL = Practical Quantitation Limit
MDL = Minimum Detection Limit
MCL = Maximum Contaminant Level
DF = Dilution Factor
ND = Analyzed for but not detected
J = Estimated result
* Federal Action Level

All samples are analyzed in accordance with
New Jersey Department of Environmental
Protection Protocol

Mark D. Feitelson, Lab. Director